

### Wattage Required To Heat Air Flows

Amt. of Air CFM	Temperature Rise (°F)										
	50	100	150	200	250	300	350	400	450	500	600
100	1.7	3.3	5.0	6.7	8.3	10.0	11.7	13.3	15.0	16.7	20.0
200	3.3	6.7	10.0	13.3	16.7	20.0	23.3	26.7	30.0	33.3	40.0
300	5.0	10.0	15.0	20.0	25.0	30.0	35.0	40.0	45.0	50.0	60.0
400	6.7	13.3	20.0	26.7	33.3	40.0	46.7	53.3	60.0	66.7	80.0
500	8.3	16.7	25.0	33.3	41.7	50.0	58.3	66.7	75.0	83.3	100.0
600	10.0	20.0	30.0	40.0	50.0	60.0	70.0	80.0	90.0	100.0	120.0
700	11.7	23.3	35.0	46.7	58.3	70.0	81.7	93.3	105.0	116.7	140.0
800	13.3	26.7	40.0	53.3	66.7	80.0	93.3	106.7	120.0	133.3	160.0
900	15.0	30.0	45.0	60.0	75.0	90.0	105.0	120.0	135.0	150.0	180.0
1,000	16.7	33.3	50.0	66.7	83.3	100.0	116.7	133.3	150.0	166.7	200.0
1,100	18.3	36.7	55.0	73.3	91.7	110.0	128.3	146.7	165.0	183.3	220.0
1,200	20.0	40.0	60.0	80.0	100.0	120.0	140.0	160.0	180.0	200.0	240.0

Use the maximum anticipated airflow. This equation assumes insulated duct (negligible heat loss) and 70° F inlet air at 14 psia.